


## BRE GLOBAL

Part of the BRE Group

Bucknalls Lane, Watford, Herts WD25 9XX

T +44 (0)1923 664100 F +44 (0)1923 664910 W [www.breglobal.com](http://www.breglobal.com)



breglobal

Halers Lighting Ltd.  
Sywell Aerodrome  
Sywell  
Northampton  
NN6 0BT

For the attention of Mr. Tony Allison

08 April 2010

Our Ref. CC261898 let 2

Dear Tony

### **Fire performance of Halers Lighting Ltd. downlights when mounted in ceilings to timber floors**

We are pleased to confirm if your lights are mounted in a ceiling to a timber floor that has been successfully tested to BS 476 : Part 21 : 1987 or BS EN 1365-1 : 1999 for 30 minutes, 60 minutes or 90 minutes then the affect of adding the lights would be insignificant.

CW202 –

- i. DL/XX/F/NW
- ii. DL/XX/F/WW
- iii. DL/XX/F/NW/DIM
- iv. DL/XX/F/WW/DIM

The test evidence and justification for this opinion will be given in our report CC261898 B which will be issued shortly.

Yours sincerely,

Norman J. Macdonald  
Principal Consultant  
For and on behalf of BRE Global  
Telephone: 01923 665026  
Email: [macdonaldn@bre.co.uk](mailto:macdonaldn@bre.co.uk)