BATTERY

The programmer is fitted with a non-rechargeable, long life battery, which will maintain the programmed time settings for a minimum of ten months with the supply disconnected. THIS SHOULD BE SUFFICIENT TO COVER POWER INTERRUPTIONS DURING THE LIFE OF THE UNIT. During power interruptions the display will be blank, after 3 days the current time of day will be lost. If the programmer is not to be used for a long period of time, the switch on the rear of the unit should be returned to the BATTERY OFF position. These are both to prolong the battery life.

SERVICE AND REPAIR

This programmer is NOT user serviceable. Please do not dismantle the unit. In the unlikely event of a fault developing please refer to the RESETTING THE PROGRAMMER section of this user guide located on page 2. If this fails to resolve the problem please contact a local heating engineer or a qualified electrician.

QUESTIONS AND ANSWERS

The display only reads bAt	Turn the battery on. The switch on the rear of the unit must be in either the Fully Pumped or Gravity position.
The unit display has become frozen	This could be due to local electrical interference. Using the RESET procedure may rectify the fault.
The indicator neon fails to illuminate	Using the RESET procedure may rectify the fault. If the problem persists the programmer will need replacing.
The indicator neon will illuminate but the pump and/or boiler fails to operate	This may indicate a problem elsewhere in your system; E.g. A zone valve, etc. please contact a registered installer for advice.
There is no display on the programmer	Try the RESET procedure on page 2, if this fails to rectify the problem please have the mains supply checked
How do I know if the programmer is still under warranty	The ChannelPlus XL range comes with a 5 year guarantee from the date of manufacture. This date is located on the rear of the unit, indicated by a month over a year
How is the programmer removed from the wall	WARNING: The ChannelPlus programmer must only be removed from it's backplate by either a qualified electrician or heating engineer; The programmer plugs in to a 9 pin backplate located on the rear of the unit and is secured using 2 screws located on the top surface of the unit. Undo these screws and pull forward and down in an arc motion
When setting the programme times, the setting 'bounces' by 10 minute periods	This indicates that you have reached an existing set time period, you will be unable to set a new ON/OFF time unless there is an alteration to the existing timed period

Email: sales@horstmann.co.uk Website: www.horstmann.co.uk Horstmann Controls Limited Bristol BS4 1UP



LED INDICATOR

7 Circuit ON indicator



Horstmann's ChannelPlus H17XL - Single Channel Programmer Offers up to three programmed operating periods per day with independent Boost and Advance control.

Can be used as a direct replacement for the 425 Coronet, where the load does not exceed 3Amps and H517(Allowing for new programmer position).

The following are some of the easy to operate features:-1 or 2 Hour Boost. Advance control gives instant On/Off override Up to 3 On/Off periods in each 24 Hour operation. Programme options: Auto / All day / On constantly / Off



12 SET slider switch

13 SET Positions

RESETTING THE PROGRAMMER

Electronic equipment can in some circumstances be affected by electrical interference. If the programmer's display becomes frozen or scrambled; or if you wish to revert back to the default time settings please use the following procedure.

Lower the front flap of the unit. Press the ADVANCE and SELECT buttons together then release the buttons and the programmer will return to the preset factory settings.



FRONT COVER

The normal working position for the SET switch is in the PROG.RUN position. In order to remind the user of this, the flap is unable to be closed with the switch in any other position.

The simple instructions below are designed to help with the programming of the unit. All the following instructions require the front flap to be lowered. Please replace the flap when normal operation is required.





SPECIAL FEATURES

The SET slide switch must be in the PROG.RUN position for the following instructions.

