

Installation Instructions for: LL6580 LL6581

SAFETY

Follow the appropriate national wiring regulations. If in any doubt contact a qualified Electrician.

Disconnect from Mains supply before installation,
Maintenance or replacing the lamp.

Lamps reach maximum temperatures rapidly. Take care when adjusting, relamping or cleaning.

SLI Lighting accepts no responsibility for modified products or for the effects of cleaning solvents or for the accumulation of dust or dirt Do not interconnect Class III products with Class I or Class II. Unless otherwise marked, products are IP20(ordinary). Do not operate in damp or corrosive situations.

All products are suitable for use in ambient temperatures of 25° C. The products should not be covered with any heat insulating material, airflow around the fitting should not be restricted. Note minimum m distances to adjacent surfaces. Any enclosure which prevents normal heat dissipation may cause reduced performance, overheating or risk of fire. (see Installation Instructions for recommendations).

These products should be connected to the lighting circuit, or fused at a maximum of 5A. If a dimmer is installed it must be specifically rated as suitable for the equipment used.

After completing the installation, note the suppliers name, address and purchase date and hand this leaflet to the person responsible or lighting maintenance.

Follow these instructions carefully to ensure safe and reliable operation. In case of any queries contact your supplier. After completing the installation note the suppliers name, address and purchase date and hand this leaflet to the person responsible or lighting maintenance.

The following symbols may be found on the product or labels:

-This fitting is suitable for mounting on Normally Flammable surfaces.

E-Indicates the safest minimum distance of lamp from a flammable surface.

-Class II Double insulated. This fitting must not be Earthed.


> -Class III
Low Voltage (SELV).

Throughout these instructions the following coding may be used:


Line (L) - Brown or Red.
Neutral (N) - Blue or Black


Earth() - Green/Yellow or Bare Conductor

All Dimensions are in Millimetres




DO NOT COVER PRODUCT OR USE AS A SHELF!






Removeall (4) lamps


Remove front cover







Removeterminal block cover

Supply incoming supply cable




Supply fixing screws to suit. $(2 \times No.8 CS)$






Connect incoming cable as shown and tighten cable grip securely.

Replace terminal block cover, ensuring that no wires are trapped.



Replace front cover, ensuring that no wires are trapped.



Replace all the lamps. Do not overtighten. $4 \times 25 \text{W MAX E14 Round Satin}$





