

## Product Certification Schedule

Schedule No: 152/001/029

Licensee: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE

Factory: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE

Specification: BS 5839-1:2013 - Fire detection and fire alarm systems for buildings - Part 1 Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises. Utilizing BS 7629-1:2008

Type of Cable: Standard fire resistant cable requirements of BS 5839-1:2013 26.2(d) utilising BS 7629-1:2008, tested to BS EN 50200:2006 (PH30 classification) and to Annex E of BS EN 50200:2006. Additionally tested to BS EN 50200:2006 (PH120 classification).

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Sheath - LTS3. Insulation - EI2.

Origin Thread: Not applicable

Origin Mark: NOBURN PLATINUM

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2016

Signed for and on behalf of the British Approvals Service for Cables

*David Winterburn*

Date 21/01/2014

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004