Issue No: 1





Certificate of Product Approval

Licensee:

Ventcroft Ltd

Faraday Road

Astmoor Industrial Estate, Runcorn, WA7 1PE, Cheshire, United Kingdom

Factory: Faraday Road

Astmoor Industrial Estate, Runcorn, WA7 1PE, Cheshire, United Kingdom

Standard: BS 7629-1:2015

Description: Fire resistant screened cables

Details:

ENHANCED 120. Additionally tested to BS 6387 Categories C, W & Z.

Materials: Insulation El 2, Sheath LTS 3

> Brand Name: N/A

Origin Mark:

NOBURN PLUS

Signed for and on behalf of the British Approvals

racie Hunter. Date: 09/12/2019

Permissible Approval Marks:





BASEC name

BASEC roundel





Expiry date: 09/12/2022



Date of original issue: 10/01/2013 Check BASEC website to verify validity.

Service for Cables





Certificate No: 152/001/049

Issue No: 1

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	N/A	2	1	1
2	N/A	N/A	2	1.5	4
2	N/A	N/A	3	1.5	4
2	N/A	N/A	4	1.5	4

Signed for and on behalf of the British Approvals Service for Cables

Date: 09/12/2019

Date of original issue: 10/01/2013 Check BASEC website to verify validity.

Page 2 of 2 BASEC, Presley House, Presley Way, Milton Keynes, MK8 DES, Registered in England No. 1150237, Tel: +44(0)1908267300 Email: mail@basec.org.uk, Web: www.basec.org.uk

