

# Loss Prevention Certification Board



## This is to certify

### **VENTCROFT LTD**

Goddard Road, Astmoor Industrial Estate, Runcorn WA7 1NQ

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

### **NoBurn Diamond**

(refer to attached appendix for details)

has complied with the requirements of the following:

**BS 7629-1:1997 (Incorporating Amendment No.1) - 300/500 V fire resistant electric cables having low emission of smoke and corrosive gases when affected by fire - Multicore cables.**

**BS 6387:1994 - Performance requirements for cables required to maintain circuit integrity under fire conditions.**

**Enhanced fire resistant cables as described in Clause 26.2 of BS 5839-1:2002 - Fire detection and alarm systems for buildings. Code of practice for system design, installation, commissioning and maintenance.**

and achieved:

**Class PH120 when tested in accordance with BS EN 50200:2000 - Method of test for resistance to fire of unprotected small cables for use in emergency circuits.**

Certificate No. 682b


Issue No. 02

Date of Issue 08 March 2006

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB

Name: R PHILLIPS



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.