


Certificate of Product Approval

Certificate Number: 682d Issue: 03

VENTCROFT LIMITED

Faraday Road
Astmoor Industrial Estate
Runcorn
Cheshire
WA7 1PE
UNITED KINGDOM



Product(s)

Cable Types as listed below: NoBurn Plus

See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7629-1:2015 (ENHANCED 120)

BS 6387:2013 (CWZ)

EN 50200:2015 (Class PH120)

BS 8434-2:2003+A2:2009 (120 mins)

BS 5839-1:2013 (Clause 26.2 Enhanced)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damier Ward

Damien Ward
for LPCB Certification Scheme Manager

06 January 2017

10 July 2013

Date of First issue

LPCB B



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Appendix to Certificate No: 682d VENTCROFT LIMITED

Product name						LPCB Ref. No.
NoBurn Plus						682d/01
Nominal csa of conductor (mm²)	Core Construction (excluding drain wire and earth)	BS 7629-1	BS 6387	EN 50200	BS 8434-2	BS 5839-1 Clause 26.2
1.0 ⁽¹⁾	2	ENHANCED 120 ⁽³⁾	C,W,Z	Class PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾
1.5 ⁽¹⁾	2, 3 & 4	ENHANCED 120 ⁽³⁾	C,W,Z	Class PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾
2.5 ⁽¹⁾	2, 3 & 4	ENHANCED 120 ⁽³⁾	C,W,Z	Class PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾
4.0(2)	2, 3 & 4	ENHANCED 120 ⁽³⁾	C,W,Z	Class PH120	120min ⁽⁴⁾	Enhanced ⁽⁵⁾

Uo/U 300/500V

Notes:

- 1. Solid conductor only.
- 2. Stranded conductor only.
- 3. In meeting the requirements of BS 7629-1:2015, the NoBurn Plus cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, achieved less than 0.5%HCI for the outer covering, binder tape and insulation when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
- 4. The duration of 120min when tested in accordance with BS 8434-2:2003+A2:2009 is achieved by 60min for the fire and mechanical shock phase and an additional 60min for the fire, mechanical shock and water phase.
- 5. The NoBurn Plus cables listed conform to BS 7629-1:2015, met Class PH120 when tested in accordance with EN 50200:2015 and met the 120min duration when tested in accordance with BS 8434-2:2003+A2:2009 and hence met the requirements for an enhanced fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damier Ward

Damien Ward

06 January 2017

10 July 2013

Signed for LPC

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Issue: 03